

# BACK TO BASICS



TEST for Safety



ISOLATE, Prove De-Energised and Earth HV equipment prior to work



IMPLEMENT or apply safe work practices to live LV Work



ENSURE protection from Voltage Difference



DETERMINE poles or pole structures are safe to climb



ENSURE fall arrest for restraint

COPYRIGHT © Electricity Engineers' Association



PO Box 5324, Wellington, New Zealand

Phone +64 4 473 8600 | [admin@eea.co.nz](mailto:admin@eea.co.nz) | Website [www.eea.co.nz](http://www.eea.co.nz)